

INVITATION TO BID

Addendum # 1



Department Of Executive Services
Finance and Business Operations Division
Procurement and Contract Services Section
206-684-1681 TTY RELAY: 711

ADDENDUM DATE: April 29, 2006

ITB Title: Park Bridges – Pedestrian/Stock

ITB Number: 06-054 PXR

Due Date/Time: May 5, 2006

Buyer: Paul Russell, paul.russell@metrokc.gov, 206-684-1054

Q#	Subsection	Question	Response
1	Section 4-2 Delivery	Is the delivery date really May 30, 2006	DELETE Delivery is required as soon as possible and not later than May 30, 2006 . REPLACE WITH Delivery is required as soon as possible and not later than June 30, 2006 .
2	Section 5 Technical Specifications		CLARIFICATION The following County Hydraulic Project permit language has the following restrictions per our installation locations. ADD to specifications: All treated wood shall be professionally treated and completely cured prior to installation below the OHWL to minimize leaching into the water or substrate. The use of wood treated with creosote or pentachlorophenol is not authorized.
3.	Section 5 Technical Specifications	After looking over the spec and drawings, these are wood structures. Wondering if we can go in as an alternate with steel structure with wood deck?	CLARIFICATION: The County is open to a steel structure

This ITB will be provided in alternative formats such as Braille, large print, audiocassette or computer disk for individuals with disabilities upon request.